



**PUBALI BANK LIMITED**  
**ICT OPERATION DIVISION**  
**HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.**

PBL/HO/ICTOD/QUOTATION/GENERATOR/৩২ / 2021

March 03, 2021

**Notice inviting quotation for supply of 5 KVA and 7 KVA  
Generator for different Branches/Sub Branches/Offices of our Bank.**

Sealed quotations are hereby invited from bonafied Supplier, Trader, Importer of Generator for supply of 5 KVA and 7 KVA Generator for different Branches/Sub Branches/Offices of our Bank all over Bangladesh as per following specifications:

**Specification:**

Requirements our Specification	Specification for 5 KVA	Specification for 7 KVA
Brand	Mention by the bidder	Mention by the bidder
Model	Mention by the bidder	Mention by the bidder
Country of Manufacture	Mention by the bidder	Mention by the bidder
Country of Origin	Japan	Japan
Detail Address of Manufacturer	Detail address of manufacture (Name, address & web address, attention, email address)	Detail address of manufacture (Name, address & web address, attention, email address)
Max AC Output	5 KVA	7 KVA
Alternator Type	Brushless	Brushless
No of Phase	Single Phase, 2 wire	Single Phase, 2 wire
Power Factor	1	1
Rated Voltage	200-230 Volt	200-230 Volt
Voltage Regulation	Auto, within AVR Functioning	Auto, within AVR Functioning
Engine Brand	Honda	Honda
Engine Model	Mention by the bidder	Mention by the bidder
Type	Air-cooled, 4 stroke , tough & high quality OHV Engine	Air-cooled, 4 stroke , tough & high quality OHV Engine
No of Cylinder	1	1
Ignition System	Transistorized Magneto Ignition type	Transistorized Magneto Ignition type
Engine Power Output	At rated rpm (KW/HP)	At rated rpm (KW/HP)
Fuel Option	Petrol	Petrol
Fuel tank capacity	Min 25 L	Min 18 L
Fuel consumption (L/hr)	Mention by the bidder	Mention by the bidder
Operating System	Battery Start	Battery Start
Rated RPM	Mention by the bidder	Mention by the bidder
Standard Features	Fuel Gauge, Volt meter, Ampere Meter, Pilot Lamp, Stop Switch, Oil Sensor, AC Circuit Breaker, Battery Trey	Fuel Gauge, Volt meter, Ampere Meter, Pilot Lamp, Stop Switch, Oil Sensor, AC Circuit Breaker, Battery Trey
Warranty	2 Years Full Warranty	2 Years Full Warranty
Price		


**Terms and conditions:**


- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Interested supplier/trader/importer may participate in both or individual specification of Generator.



- 3) In case of any trouble with the Generator within the warranty period the supplier shall have to replace/repair the Generator free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the Generator is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 4) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Branch/ Office as per terms of the Supply Order on production of a certificate from the concerned branch/ office to the effect that the Generator is supplied in good condition as per Supply Order and is working properly.
- 5) **10% (ten percent)** of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 6) **All Tax, Vat, Govt. Duties etc.** will be deducted from the bill as per rule prior to payment of the same.
- 7) **Successful bidder must ensure delivery of Generators within 15 (fifteen) days of getting work order.**
- 8) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 9) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank is the prime factors for consideration.
- 10) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the Generator.
- 11) Photocopy of Trade License, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer/Bid to be dropped in the Tender Box kept in **Establishment Division**, Pubali Bank Limited, Head Office, 12<sup>th</sup> Floor, 26 Dilkusha C/A, Dhaka **by 11-00 a.m.** up to **21-03-2021** which will be opened on the same day at 11.30 a.m. in presence of the bidders (if any).

  
(Md. Aminul Islam)  
Asst. General Manager

  
(Md. Helal Uddin)  
GM & Division Head

# OFFERING SHEET

(To be submitted along with the offer)

Tenderer's name :

Address :

## Tender Notice for Supply of 5 KVA Generator

Requirements our Specification	Specification	Bidder Specification
<b>Brand</b>	Mention by the bidder	
<b>Model</b>	Mention by the bidder	
<b>Country of Manufacture</b>	Mention by the bidder	
<b>Country of Origin</b>	Japan	
<b>Detail Address of Manufacturer</b>	Detail address of manufacture (Name, address & web address, attention, email address)	
<b>Max AC Output</b>	5 KVA	
<b>Alternator Type</b>	Brushless	
<b>No of Phase</b>	Single Phase, 2 wire	
<b>Power Factor</b>	1	
<b>Rated Voltage</b>	200-230 Volt	
<b>Voltage Regulation</b>	Auto, within AVR Functioning	
<b>Engine Brand</b>	Honda	
<b>Engine Model</b>	Mention by the bidder	
<b>Type</b>	Air-cooled, 4 stroke , tough & high quality OHV Engine	
<b>No of Cylinder</b>	1	
<b>Ignition System</b>	Transistorized Magneto Ignition type	
<b>Engine Power Output</b>	At rated rpm (KW/HP)	
<b>Fuel Option</b>	Petrol	
<b>Fuel tank capacity</b>	Min 25 L	
<b>Fuel consumption (L/hr)</b>	Mention by the bidder	
<b>Operating System</b>	Battery Start	
<b>Rated RPM</b>	Mention by the bidder	
<b>Standard Features</b>	Fuel Gauge, Volt meter, Ampere Meter, Pilot Lamp, Stop Switch, Oil Sensor, AC Circuit Breaker, Battery Trey	
<b>Warranty</b>	2 Years Full Warranty	
<b>Price</b>		

-----  
**Authorized Signature**

# OFFERING SHEET

(To be submitted along with the offer)

Tenderer's name :

Address :

## Tender Notice for Supply of Generator

Sl	Specification	
1	Max. AC output	: 7 KVA
	Brand	:
	Model	:
	Phase	: Single, 2 Wire
	Engine Type	: Air-cooled, 4 stroke, Tough & high quality OHV Engine
	Starting System	: Electric and Recoil both
	Fuel Tank capacity	: Minimum 18L
	Fuel Consumption per hour	:
	Country of manufacture	:
	Country of origin	: Japan
	Warranty (02 years or more)	:
2	Unit Price	:
	(Including required change-over-switch & necessary electrical wiring, delivery & installation all over the country in Bangladesh)	

-----  
**Authorized Signature**