



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/2 KVA ONLINE UPS/ ¹¹⁸³ / 2022

March 23, 2022

**Notice inviting quotation for supply of 02 (Two) KVA
Online UPS for different Branches/Banking Booths of our Bank.**

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 2 KVA Online UPS for different Branches/Banking Booths of our Bank as per following specification.

Specification for 2KVA (10/10) Online UPS:


SN	Feature	Product Description	Price		
1	General	Online UPS 2KVA (Low Frequency), 1Phase In & 1Phase Out and Ground	Tk.		
		Brand		Bidder Mention	
		Model		Bidder Mention	
		Country of Origin		Bidder Mention	
		Country of Manufacture		Bidder Mention	
		Capacity		2 KVA (Low Frequency)	
		Backup		3 Hours (Full Load) at 1800W bulb / Heater test.	
	Input	Input voltage range		110-280Vac (Full Load)	
		Input Phase		1 Phase	
		Generator Input		Support	
	Output	Output Phase		1 Phase and Ground	
		Output voltage range		220/230/240 VAC +/-1%	
		Frequency		50Hz	
		Power Factor		0.9	
	Battery & Charger	System Unit Voltage		96 Vdc or more	
		Battery Brand		LONG /DIAMEC /LEOCH /ZIGOR /ROCKET	
		Battery Weight (Minimum)		7.5A—2.2Kg /9A—2.5Kg/12A—3.8Kg/18A—4.5Kg/26A—7Kg/40A—12.5Kg/60A—18Kg/70A—19Kg/80A—21Kg/100A—28Kg/120A—32Kg/150A—48Kg/200A—52Kg or more weight.	
		Quantity		Bidder Mention	
		Capacity		Bidder Mention	
		Battery Type		Sealed Maintenance Free (SMF)	
		Charge Current		Built-in : 12A or Higher	
	Other Features	Maintenance Bypass Switch		Built-in	
		Monitoring System		LED Display	
		Generator Support		Yes	
	Accessories	Manual Bypass DB		Yes (Must be)	
		Electrical wire (BRB /Estern /BBS /SQ /Partex /Paradise /Singer etc)		To complete install online UPS.	
		Circuit Breaker (ABB /Legrand /Schneider etc)		To complete install online UPS.	
		Raw material		DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape etc.	
	Site Visit	Pre inspection		Site visit preferred, if supplier are interested.	
	Warranty	System Unit & Battery		2 Year Full warranty (System Unit & Battery)	
	Unit Price (Including VAT & IT)	Price are included with Installation Charge, Electrical wire, Circuit Breaker, Raw materials and others if needed.		Tk.	




Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) **The UPS to be supplied to Hardware Section of ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the PBTI as per terms of the Supply Order on production of a certificate from the concerned PBTI to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the PBTI where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) **Successful bidder** must ensure delivery of UPS **within 15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, and reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 06-04-2022** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).


(Md. Aminul Islam)
Asst. General Manager


(Md. Helal Uddin)
GM & Division Head

OFFERING SHEET
(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 02 KVA Online UPS for different Branches/Banking Booths.

SN	Feature	Product Description	Price	
1	General	Online UPS 2KVA (Low Frequency), 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		2 KVA (Low Frequency)
		Backup		3 Hours (Full Load) at 1800W bulb / Heater test.
	Input	Input voltage range		110-280Vac (Full Load)
		Input Phase		1 Phase
		Generator Input		Support
	Output	Output Phase		1 Phase and Ground
		Output voltage range		220/230/240 VAC +/-1%
		Frequency		50Hz
		Power Factor		0.9
	Battery & Charger	System Unit Voltage		96 Vdc or more
		Battery Brand		LONG /DIAMEC /LEOCH /ZIGOR /ROCKET
		Battery Weight (Minimum)		7.5A—2.2Kg /9A—2.5Kg/12A—3.8Kg/18A—4.5Kg/26A—7Kg/40A—12.5Kg/60A—18Kg/70A—19Kg/80A—21Kg/100A—28Kg/120A—32Kg/150A—48Kg/200A—52Kg or more weight.
		Quantity		Bidder Mention
		Capacity		Bidder Mention
		Battery Type		Sealed Maintenance Free (SMF)
		Charge Current		Built-in : 12A or Higher
	Other Features	Maintenance Bypass Switch		Built-in
		Monitoring System		LED Display
		Generator Support		Yes
	Accessories	Manual Bypass DB		Yes (Must be)
		Electrical wire (BRB /Estern /BBS /SQ /Partex /Paradise /Singer etc)		To complete install online UPS.
		Circuit Breaker (ABB /Legrand /Schneider etc)		To complete install online UPS.
		Raw material		DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape etc.
	Site Visit	Pre inspection		Site visit preferred, if supplier are interested.
	Warranty	System Unit & Battery		2 Year Full warranty (System Unit & Battery)
Unit Price (Including VAT & IT)	Price are included with Installation Charge, Electrical wire, Circuit Breaker, Raw materials and others if needed.		Tk.	

Authorized Signature

