

PUBALI BANK LIMITED

ICT OPERATION DIVISION HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/UPS/

(2020) / 2020

July 29, 2020

Notice inviting quotation for supply of 1 KVA UPS (AVR Built in) for different Branches/Offices of Pubali Bank Limited all over Bangladesh.

Sealed quotations are hereby invited from bonafide Manufacture or its Agent, Supplier, Trader of UPS for supply of AVR built in UPS for different Branches/Offices of Pubali Bank Ltd. all over Bangladesh as per following specifications.

Specifications of the UPS (AVR Built in):

SI	Specification details				
1	Brand		Renowned brand		
2	Model		Bidder Mention		
3	Capacity		1000VA		
4	Bulb Test		700 Watt		
5	Backup Time		Minimum 15 Minutes (Full Load)		
6	Input Voltage range		160V-275V AC		
7	Output Voltage range	:	180V-235V AC		
8	Frequency of UPS (Line)) : 50Hz			
9	Frequency of UPS (Inverter)	:	50Hz		
10	Frequency of Generator	:	50Hz		
11	Battery type (Mention Brand, Volt. Amp, Qnt'y)	:	Maintenance free Seal type		
12	Country of Manufacture	:	Taiwan / China / Bangladesh		
13	Warranty	:	2(two) years full Warranty		

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

Terms and conditions:

- 1) The offer must be submitted through "Offering Sheet" enclosed with the schedule.
- 2) The UPS will be under comprehensive Warranty for **full 2(two) years** or above from the date of supply.
- 3) The UPS to be supplied to Hardware Section of ICT Operation Division, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) 10% (ten percent) of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.



- 6) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 7) Payment of the bills will be made from ICT Operation Division, Head Office, after delivery of the same at the Branch/ Office as per terms of the Supply Order on production of a certificate from the concerned branch/ office to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 8) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 9) Successful bidder must ensure delivery of UPSs within 15 (fifteen) days of getting workorder.
- 10) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the <u>Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 7th Floor, 26 Dilkusha C/A, Dhaka by 11:00 a.m. up to 16-08-2020 which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).</u>

Sd/-

Sd/-

(Md. Aminul Islam) Asst. General Manager (Md. Helal Uddin) GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office,

Dhaka for information and necessary action.

CC TO: Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CCTO: www.pubalibangla.com

Asst. General Manager

Middle GM & Division Head

OFFERING SHEET

(To be submitted alongwith the offer)

Tenderer's Name

Address

Tender Notice for supply of 1000 VA UPS.

Sl.	Description	Required Specification	Bidder Specification	Unit Price
1	Brand	Renowned brand		
2	Model	Bidder Mention		
3	Capacity	1000VA		
4	Bulb Test	700 Watt		
5	Backup Time	Minimum 15 Minutes (Full Load)		N.
6	Input Voltage range	160V-275V AC		
7	Output Voltage range	180V-235V AC		
8	Frequency of UPS (Line)	50Hz		
9	Frequency of UPS (Inverter)	50Hz		
10	Frequency of Generator	50Hz		
11	Battery type (Mention Brand, Volt. Amp, Qnt'y)	Maintenance free Seal type		~
12	Country of manufacturer	Taiwan / China / Bangladesh		
13	Warranty	2 (Two) years full warranty		