



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/40 KVA ONLINE UPS/201213/2020

August 10, 2020

**Notice inviting quotation for supply of 40 (Forty) KVA
Online UPS for Central Accounts Division, Head Office, Dhaka.**

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 40 KVA Online UPS for Central Accounts Division, Head Office, Dhaka as per following specification.

Specifications of the UPS:

Product Specification		
Brand	Bidder mention	
Model	Bidder mention	
Country of Manufacture	Bidder mention	
Capacity	40KVA (3 in 3 Out)	
Backup Time	15 Minutes backup at full load	
Efficiency	To AC Mode	87%
	To Battery Mode	83%
Input	Frequency Range	50Hz-60Hz
	Power Factor	0.80 @ nominal voltage (100% load)
	Voltage range	340AC-400AC
BATTERY	Battery Type	Maintenance free battery
	Battery Amp	Bidder mention
	Numbers of Battery	Bidder mention
	Typical Recharge Time	Bidder mention
OUTPUT	Output Voltage	220VAC
	Frequency Range (Synchronized Range)	50 Hz
	Transfer Time	Line mode to Battery mode Zero
	Waveform (Batt. Mode)	Pure Sine Wave
INDICATORS	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions
MANAGEMENT	Built-in SNMP	Power management from SNMP manager and web browser
	Smart RS-232/USB	Supports Windows® 2000/2003/XP/Vista/2008, Windows® 7, Linux, and MAC
CONNECTION	Input Connection	5 wires, 3 Phase + N + PE
	Output Connection	5 wires, 3 Phase + N + PE
Accessories	Electrical wire : Red-----6rm-----1 Coil Yellow-----6rm-----1 Coil Blue-----6rm-----1 Coil Black-----6rm-----1 Coil Green-----4rm-----1 Coil Electrical cable Brand (Original): BRB/BBS/Paradise/Estern/Pertex/S	



	<p>Q etc.</p> <p>Circuit Breaker (3 Phase) -----3 Pcs, Circuit Breaker (1 Phase) -----3 Pcs,</p> <p>Circuit Breaker (Original): ABB/Legrand/schneider etc.</p> <p>In addition DB Box, connector & others will be added if needed.</p> <p>We are request to you for pre inspection site visit.</p>	
Installation charge	Price will Included with Unit Price	
Warranty	02 Years full (System Unit + Battery)	

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned Division.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Central Accounts Division, Head Office, Dhaka as per terms of the Supply Order on production of a certificate from the concerned Division to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) Successful bidder must ensure delivery of UPS within **15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.



Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 23-08-2020** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).


Sd/-
(Md. Aminul Islam)
Asst. General Manager

Sd/-
(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head



OFFERING SHEET

(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 40 (Forty) KVA Online UPS**Specifications of the UPS:****Product Specification**

Brand	Bidder mention	
Model	Bidder mention	
Country of Manufacture	Bidder mention	
Capacity	40KVA (3 in 3 Out)	
Backup Time	15 Minutes backup at full load	
Efficiency	To AC Mode	87%
	To Battery Mode	83%
Input	Frequency Range	50Hz-60Hz
	Power Factor	0.80 @ nominal voltage (100% load)
	Voltage range	340AC-400AC
BATTERY	Battery Type	Maintenance free battery
	Battery Amp	Bidder mention
	Numbers of Battery	Bidder mention
	Typical Recharge Time	Bidder mention
OUTPUT	Output Voltage	220VAC
	Frequency Range (Synchronized Range)	50 Hz
	Transfer Time	Line mode to Battery mode Zero
	Waveform (Batt. Mode)	Pure Sine Wave
INDICATORS	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions
MANAGEMENT	Built-in SNMP	Power management from SNMP manager and web browser
	Smart RS-232/USB	Supports Windows® 2000/2003/XP/Vista/2008, Windows® 7, Linux, and MAC
CONNECTION	Input Connection	5 wires, 3 Phase + N + PE
	Output Connection	5 wires, 3 Phase + N + PE
Accessories	Electrical wire : Red-----6mm-----1 Coil Yellow-----6mm-----1 Coil Blue-----6mm-----1 Coil Black-----6mm-----1 Coil Green-----4mm-----1 Coil Electrical cable Brand (Original):	



	<p>BRB/BBS/Paradise/Estern/Pertex/SQ etc.</p> <p>Circuit Breaker (3 Phase) -----3 Pcs, Circuit Breaker (1 Phase) -----3 Pcs,</p> <p>Circuit Breaker (Original): ABB/Legrand/schneider etc.</p> <p>In addition DB Box, connector & others will be added if needed.</p> <p>We are request to you for pre inspection site visit.</p>		
Installation charge	Price will Included with Unit Price		
Warranty	02 Years full (System Unit + Battery)		
Price (Including VAT & AIT)			

Authorised Signature: