



PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/40 KVA ONLINE UPS/ 2020

December 26, 2021

Notice inviting quotation for supply of 40 (Forty) KVA Online UPS for Credit Administration Monitoring & Recovery Division, Head Office, Dhaka.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 40 KVA Online UPS for Central Accounts Division, Head Office, Dhaka as per following specification.

Specifications of the UPS:

Product Specification		
Brand	APC /RIELLO /SCHNEIDER /ABB /VERTIV /ZIGOR /KSTAR	
Model	Bidder mention	
Country of Manufacture	Bidder mention	
Capacity	40KVA (3/3 Phase)	
Backup Time	30 Minute backup at full load	
Input	Voltage range	380/400/415 VAC
	Frequency Range	46Hz-54Hz
Output	Output Voltage	220VAC
	Frequency Range	50Hz
	Transfer Time	Line mode to Battery mode Zero
	Waveform (Battery Mode)	Pure Sine Wave
	System Voltage	240 Volt
Battery	Battery Type	SMF
	Numbers of Battery	Minimum 20Pcs
	Battery Amp	Minimum 26A, 12Volt
	Typical Recharge Time	Bidder mention
Noise Level	<60dB	
Generator Support	Yes	
Indicators	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions
Management	SNMP (Built-in)	Power management from SNMP manager and web browser
Connection	Input Connection	5 wires, 3 phase + N + PE
	Output Connection	5 wires, 3 phase + N + PE
Maintenance Bypass	Manual with Ckt Breaker	Manual with Ckt Breaker
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.	
Warranty	02 Years full (System Unit + Battery)	
Unit Price	Price will Included with VAT, AIT & Security Money.	

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

2/



Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned Division.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Central Accounts Division, Head Office, Dhaka as per terms of the Supply Order on production of a certificate from the concerned Division to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) Successful bidder must ensure delivery of UPS within **15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 12-01-2021** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-
(Md. Aminul Islam)
Asst. General Manager

Sd/-
(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office,
Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head

OFFERING SHEET
(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 40 (Forty) KVA Online UPS

Product Specification			
Brand	APC /RIELLO /SCHNEIDER /ABB /VERTIV /ZIGOR /KSTAR		
Model	Bidder mention		
Country of Manufacture	Bidder mention		
Capacity	40KVA (3/3 Phase)		
Backup Time	30 Minute backup at full load		
Input	Voltage range	380/400/415 VAC	
	Frequency Range	46Hz-54Hz	
Output	Output Voltage	220VAC	
	Frequency Range	50Hz	
	Transfer Time	Line mode to Battery mode Zero	
	Waveform (Batt. Mode)	Pure Sine Wave	
	System Voltage	240 Volt	
Battery	Battery Type	SMF	
	Numbers of Battery	Minimum 20Pcs	
	Battery Amp	Minimum 26A, 12Volt	
	Typical Recharge Time	Bidder mention	
Noise Level	<60dB		
Generator Support	Yes		
Indicators	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions	
Management	SNMP (Built-in)	Power management from SNMP manager and web browser	
Connection	Input Connection	5 wires, 3 phase + N + PE	
	Output Connection	5 wires, 3 phase + N + PE	
Maintenance Bypass	Manual with Circuit Breaker		
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.		
Warranty	02 Years full (System Unit + Battery)		
Unit Price (Include VAT, AIT & Security Money)	Price will Included with Installation charge @Motijheel C/A.		

Authorized Signature