



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/2 KVA UPS/ 528(3) / 2019

March 04, 2019

**Notice inviting quotation for supply of 2(two) KVA offline UPS
for Communication Devices for Online Branches of our Bank.**

Sealed quotations are hereby invited from bonafide Manufacture or its Agent, Supplier, Trader of UPS for supply of 2 KVA UPS for communication devices (Router, Switch and Media convertors) for Online Branches of our Bank as per following specification.

Specifications of the UPS:

Sl	Specification details	
1	Capacity	: 2 KVA (2000 VA) Offline
2	Bulb Test	: 1400 Watt full load
3	Backup Time	: 2 hours at full load
4	Input Voltage	: 170V-275V AC
5	Output Voltage	: 220V ± 5% AC
6	Battery type	: Maintenance Free
7	Input Voltage Protector	: Circuit Breaker
8	Output Voltage Protector	: Fuse, Surge Protector
9	Output Socket	: 4 PCs
10	Warranty	: 2(two) years full warranty with Battery Bank
11	Country of origin	: Bangladesh/China

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) The UPS including Battery will be under comprehensive warranty for **full 2 (two) years** or above from the date of installation at the location where it will be supplied.
- 3) **The UPS to be supplied to Hardware Section of ICT Operation Division, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.**
- 4) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.

OFFERING SHEET
(To be submitted alongwith the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 2(two) KVA offline UPS.

Sl	Specification details		Unit Price
1	Capacity	:	
2	Bulb Test	:	
3	Backup Time	:	
4	Input Voltage	:	
5	Output Voltage	:	
6	Battery type	:	
7	Input Voltage Protector	:	
8	Output Voltage Protector	:	
9	Output Socket	:	
10	Warranty	:	
11	Country of origin	:	

Authorised Signature