



PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/UPS/ 530(3) / 2019

March 04, 2019

Notice inviting quotation for supply of 1 KVA UPS (AVR Built in) for different Branches/Offices of Pubali Bank Limited all over Bangladesh.

Sealed quotations are hereby invited from bonafide Manufacture or its Agent, Supplier, Trader of UPS for supply of AVR built in UPS for different Branches/Offices of Pubali Bank Ltd. all over Bangladesh as per following specifications.

Specifications of the UPS (AVR Built in) :

Sl	Specification details	
1	Brand	: Renowned brand
2	Model	: Bidder Mention
3	Capacity	: 1000VA
4	Bulb Test	: 700 Watt
5	Backup Time	: Minimum 15 Minutes (Full Load)
6	Input Voltage range	: 160V-275V AC
7	Output Voltage range	: 180V-235V AC
8	Frequency of UPS (Line)	: 50Hz
9	Frequency of UPS (Inverter)	: 50Hz
10	Frequency of Generator	: 50Hz
11	Battery type (Mention Brand, Volt. Amp, Qnt'y)	: Maintenance free Seal type
12	Country of Manufacture	: Taiwan / China / Bangladesh
13	Warranty	: 2(two) years full Warranty

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) The UPS will be under comprehensive Warranty for **full 2(two) years** or above from the date of supply.
- 3) The UPS to be supplied to Hardware Section of ICT Operation Division, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent)** of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.

OFFERING SHEET
(To be submitted alongwith the offer)

Tenderer's Name :

Address :

Tender Notice for supply of 1000 VA UPS.

Sl.	Description	Required Specification	Bidder Specification	Unit Price
1	Brand	Renowned brand		
2	Model	Bidder Mention		
3	Capacity	1000VA		
4	Bulb Test	700 Watt		
5	Backup Time	Minimum 15 Minutes (Full Load)		
6	Input Voltage range	160V-275V AC		
7	Output Voltage range	180V-235V AC		
8	Frequency of UPS (Line)	50Hz		
9	Frequency of UPS (Inverter)	50Hz		
10	Frequency of Generator	50Hz		
11	Battery type (Mention Brand, Volt. Amp, Qnt'y)	Maintenance free Seal type		
12	Country of manufacturer	Taiwan / China / Bangladesh		
13	Warranty	2 (Two) years full warranty		

Authorised Signature