



PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/GENERATOR/ 531(3)/2019

March 04, 2019

Notice inviting quotation (2nd Time) for supply of Max. AC output 7 KVA Generator for different Branches/Offices of Pubali Bank Ltd.

Sealed quotations are hereby invited from bonafied Supplier, Trader, Importer of Generator for supply of max. AC output 7 KVA Generator for different Branches/Offices of Pubali Bank Ltd. all over Bangladesh as per following specifications:

Specification:

Brand: Mention by the bidder, **Model:** Mention by the bidder, **Country of Manufacture:** Mention by the bidder, **Country of Origin:** Japan, Detail address of manufacturer (Name, address, & Web address, attention, email etc), **Max AC output:** 7 KVA, **Alternator Type:** Brushless, **No. of phase:** Single phase, 2 wire, **Power Factor:** 1, **Rated Voltage:** 200-230Volt, **Voltage Regulation:** Auto, within AVR Functioning, **Engine Brand:** Honda, **Engine Model:** Mention by the bidder, **Type:** Air-cooled, 4 stroke, tough & high quality OHV Engine, **No. of Cylinder:** 1, **Ignition System:** Transistorized Magneto Ignition type, **Engine Power Output:** At rated rpm (KW/HP), **Fuel Option:** Petrol, **Fuel tank capacity:** Minimum 18L, **Fuel consumption (L/hr):** Mention by the bidder, **Operating System:** Battery Start, **Rated RPM:** Mention by the bidder, **Standard Features:** Fuel Gauge, Volt Meter, Ampere Meter, Pilot Lamp, Stop Switch, oil sensor AC Circuit Breaker, Battery Tray, **Warranty:** 2 years full warranty.

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) The Generator will be under comprehensive **Warranty for full 02(two) years or more** from the date of installation at the Branch/Office where it will be supplied.
- 3) In case of any trouble with the Generator within the warranty period the supplier shall have to replace/repair the Generator free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the Generator is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 4) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Branch/ Office as per terms of the Supply Order on production of a certificate from the concerned branch/ office to the effect that the generator is supplied in good condition as per Supply Order and is working properly.

OFFERING SHEET

(To be submitted along with the offer)

Tenderer's name :

Address :

Tender Notice (2nd Time) for Supply of Generator

Sl	Specification	
1	Max. AC output	: 7 KVA
	Brand	:
	Model	:
	Phase	: Single, 2 Wire
	Engine Type	: Air-cooled, 4 stroke, Tough & high quality OHV Engine
	Starting System	: Electric and Recoil both
	Fuel Tank capacity	: Minimum 18L
	Fuel Consumption per hour	:
	Country of manufacture	:
	Country of origin	: Japan
	Warranty (02 years or more)	:
2	Unit Price (Including required change-over-switch & necessary electrical wiring, delivery & installation all over the country in Bangladesh)	:

Authorized Signature