



PUBALI BANK PLC.
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBPLC./HO/ICTOD/QUOTATION/20 KVA ONLINE UPS/ 2024

March 24, 2024

**Notice inviting quotation for supply of 20 (Twenty) KVA Online UPS
for SQA Team of ICT Operation Division, BIWTC Bhaban, Motijheel, Dhaka.**

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 20 KVA Online UPS for SQA Team of ICT Operation Division, BIWTC Bhaban, Motijheel, Dhaka as per following specification.

Specifications of the UPS:

Product Specification		
Brand	APC /RIELLO /ABB /ENSMART	
Model	Bidder mention	
Country of Manufacture	EU /Switzerland /UK /Taiwan	
Capacity	20KVA (3/3 Phase)	
Backup Time	60 Minute backup at Heater load	
Input	Voltage range (P-P)	380/400/415 VAC
	Frequency Range	46Hz-54Hz
Output	Output Voltage (P-P)	380/400/415 VAC
	Frequency Range	50Hz
	Transfer Time	Line mode to Battery mode Zero
	Waveform (Battery Mode)	Pure Sine Wave
	System Voltage	Bidder mention
Battery	Battery Type	SMF
	Numbers of Battery	Bidder mention
	Battery Amp	Minimum 65A or More
	Typical Recharge Time	Bidder mention
Noise Level	<60dB	
Generator Support	Yes	
Indicators	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions
Management	SNMP (Built-in)	Power management from SNMP manager and web browser
Connection	Input Connection	5 wires, 3 phase + N + PE
	Output Connection	5 wires, 3 phase + N + PE
Maintenance Bypass	Manual with Ckt Breaker	Manual with Ckt Breaker
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.	6rm 1 Coil (Red), 6rm 1 Coil (Yellow), 6rm 1 Coil (Blue), 6rm 1 Coil (Black), 4rm 1 Coil (Green) and connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.
Warranty	02 Years full (System Unit + Battery)	
Unit Price	Price will Included with VAT, AIT & Security Money.	

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

Terms and conditions:



- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) **Successful bidder must have an account i.e. SB/CD/CC at any Branch of our Bank for receiving their payment through online.**
- 7) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the PBTI as per terms of the Supply Order on production of a certificate from the concerned PBTI to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 8) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the PBTI where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 9) Successful bidder must ensure delivery of UPS within **15 (fifteen) days** of getting work order.
- 10) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 11) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, and reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 12) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the UPS.
- 13) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment and General Services Division, Pubali Bank PLC., Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 21-04-2024** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).


Sd/-
(Md. Aminul Islam)
Asst. General Manager

Sd/-
(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank PLC., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank PLC., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head

OFFERING SHEET

(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 20 (Twenty) KVA Online UPS for SQA Team of ICT Operation Division

Product Specification	
Brand	APC /RIELLO /ABB /ENSMART
Model	Bidder mention
Country of Manufacture	EU /Switzerland /UK /Taiwan
Capacity	20KVA (3/3 Phase)
Backup Time	60 Minute backup at Heater load
Input	Voltage range (P-P)
	Frequency Range
Output	Output Voltage (P-P)
	Frequency Range
	Transfer Time
	Waveform (Battery Mode)
	System Voltage
Battery	Battery Type
	Numbers of Battery
	Battery Amp
	Typical Recharge Time
Noise Level	<60dB
Generator Support	Yes
Indicators	LED Panel
Management	SNMP (Built-in)
Connection	Input Connection
	Output Connection
Maintenance Bypass	Manual with Ckt Breaker
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.
Warranty	02 Years full (System Unit + Battery)
Unit Price	Price will Included with VAT, AIT & Security Money.

Authorized Signature