



PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/40 KVA ONLINE UPS/ 2019/2019

May 20, 2019

Notice inviting quotation for supply of 40 (Forty) KVA Online UPS for Principal Branch, 26 Dilkusha C/A, Dhaka.


Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 40 KVA Online UPS for Principal Branch, 26 Dilkusha C/A, Dhaka as per following specification.

Specifications of the UPS:

Brand : Mentioned by the bidder, **Model**: Mentioned by the bidder, **Country of Manufacture** : Mentioned by the bidder, **Capacity** : 40KVA, **Backup time**: 15 Min, **Input Nominal voltage** : 380/400/415Vac (3Ph+N+PE), **Input Operating voltage range** :208-478Vac, **Input Operating frequency range** : 45-55Hz at 50Hz, **Input Power factor** : ≥ 0.99 , **Output Voltage** : 380/400/415Vac (3Ph+N+PE), **Output Power factor** : 0.9, **Output Voltage regulation** : 0.9, **Output Frequency (Bat. Mode)** : 50Hz, **Output Frequency (Line Mode)** : $\pm 10\%$ of the rated frequency (Optional), **Output Crest factor** : 3:1, **Output Efficiency** : 94.5%, **Battery Voltage** : Standard Unit Voltage ($\pm 96Vdc/\pm 108Vdc/\pm 120Vdc$), **Battery Charge Current (A)**: 4.05A /15A, **Battery Type** : Maintenance free battery, **Numbers of Battery** (12V, 26A or above) : Mentioned by the bidder, **Battery Bank** : Box sheet 16Gaes with wheels, **Transfer time** : Utility to Battery : 0ms; Utility to bypass : 0ms; **Overload** : Load $\leq 110\%$:last 60min, $\leq 125\%$:last 10min, $\leq 150\%$:last 1min, 150% change to bypass, **Short Circuit** : Hold Whole System, **Communication** : USB, RS232, RS485, SNMP Card (Built in), **Indicators (LED Panel)** : UPS status, Load level, Battery level, Input/ Output voltage, and Fault conditions, **Humidity range**: 0-95% (Non condensing), **Noise level**: <63dB, **Input Connection**: 5 wires (3 phase + N + PE), **Output Connection** : 3 wires (1 phase + N + PE), **Accessories** : Electrical wire (Red+Yellow+Blue+Black) 6mm & Electrical wire (Green) 4mm, Electrical cable Brand (Original): BRB/BBS/Paradise/Estern/Pertex/SQ etc. Circuit Breaker (3 Phase)-3Pcs, Circuit Breaker (1 Phase)--1 Pc, Circuit Breaker (Original): ABB/Legrand/schneider etc. In addition DB Box, connector & others will be added if needed. **Installation Charge** : Price will Included with Unit Price, **Warranty** : 02 Years full (System Unit + Battery) details as per specification.

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Principal Branch, Dhaka as per terms of the Supply Order on production of a certificate from the concerned Branch to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to



replace/repair the UPS free of cost at the premises where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.

- 8) Successful bidder must ensure delivery of UPS within **15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 12-06-2019** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-
(Md. Aminul Islam)
Asst. General Manager


Sd/-
(Md. Helal Uddin)
General Manager

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


General Manager

OFFERING SHEET

(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 40 (Forty) KVA Online UPS

SN	Technical specification	Bidder's Specification	Unit Price
1	Brand	Bidder mention	
2	Model	Bidder mention	
3	Country of Manufacture	Bidder mention	
4	Capacity	40KVA	
5	Backup Time	15 Minutes backup at full load	
6	Input	Nominal voltage	380/400/415Vac (3Ph+N+PE)
		Operating voltage range	208-478Vac
		Operating frequency range	45-55Hz at 50Hz
		Power factor	≥0.99
7	OUTPUT	Output Voltage	380/400/415Vac (3Ph+N+PE)
		Power factor	0.9
		Voltage regulation	±1%
		Frequency (Bat. Mode)	50Hz
		Frequency (Line Mode)	±10% of the rated frequency (Optional)
		Crest factor	3:1
		Efficiency	94.5%
8	BATTERY	Battery Voltage	Standard Unit Voltage (±96Vdc/ ±108Vdc/ ±120Vdc)
		Charge Current (A)	4.05A /15A
		Battery Type	Maintenance free battery
		Numbers of Battery	12V, 26A above
		Battery Bank	Box sheet 16Gaes with wheels
9	SYSTEM FEATURES	Transfer time	Utility to Battery : 0ms; Utility to bypass : 0ms;
		Overload	Load ≤110%: last

			60min, ≤125%: last 10min, ≤150%: last 1min, 150% change to bypass.	
		Short Circuit	Hold Whole System	
		Communication	USB, RS232, RS485, SNMP Card (Built in)	
10	INDICATORS	LED Panel	UPS status, Load level, Battery level, Input/ Output voltage, and Fault conditions	
11	ENVIRONMENTAL	Humidity range	0-95% (Non condensing)	
		Noise level	<63dB	
12	CONNECTION	Input Connection	5 wires, 3 phase + N + PE	
		Output Connection	3 wires, 1 phase + N + PE	
13	Accessories	<p>Electrical wire (length at actual) : (Red+Yellow+Blue+Black) 6rm & (Green) 4rm,</p> <p>Electrical cable Brand (Original): BRB/BBS/Paradise/Estern/Pertex/SQ etc.</p> <p>Circuit Breaker (3 Phase) -----3 Pcs, Circuit Breaker (1 Phase) -----1 Pcs, Circuit Breaker (Original): ABB/Legrand/schneider etc.</p> <p>In addition DB Box, connector & others will be added if needed.</p> <p>We are request to you for pre inspection site visit.</p>		
14	Installation Charge	Price will Included with Unit Price	Price will Included with Unit Price	
15	Warranty	02 Years full (System Unit + Battery)		
16	Price			