



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/5 KVA ONLINE UPS/2020

August 24, 2020

Notice inviting quotation for supply of 05 (five) KVA
Online UPS for different Branches/Banking Booths of our Bank.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 5 KVA Online UPS for different Branches/Banking Booths of our Bank as per following specification.

Specification for 5KVA (10/10) Online UPS:

SN	Feature	Product Description	Price	
1	General	True On Line UPS 5KVA, 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		5KVA
		Backup		1 hours (Full Load)
	Input	Input voltage range		120-276Vac (Full Load)
		Nominal Voltage		220Vac (1Phase, 2 wire +G)
		Power Factor		>0.99 (full load)
		Frequency		40~70Hz (Auto detect)
		Input Phase		1 Phase
		Current THDi		< 5% at non-linear load
		Bypass Voltage Range		Max. Voltage: +15% Min. voltage : -45% Frequency protection range: ±10%
		ECO Range		Same as the bypass
		Generator Input		Support
		Output		Output Phase
	Output voltage range			220volt ±1%
	Voltage Regulation			±2%
	Frequency			50Hz
	THD			≤2% with linear load ≤5% with non-linear load
	Crest Factor			3:1
	Power Factor			0.8
	Overload Capacity			≤105%: continuous; 106%~110%:10 minute; 111%~125%:1 minute; 125%~150%:30 seconds
	Waveform			Pure Sinewave
	Battery & Charger			System Unit Voltage
		Quantity		16Pcs/18Pcs/20Pcs
		Capacity		Bidder Mention
		Battery Type		Sealed Maintenance Free (SMF)
	Conformance	Charge Current		Built-in :1A or Higher
		Safety		CE
	Efficiency	AC-AC		≥90%
		ECO Mode		≥98%
	Environment	Operating Temperature		0~45°C
		Storage Temperature		-25~55°C
		Relative Humidity		0~95% (non-condensing)
		Audible Noise		<60dB (at 1 meter)
	Communication Interface	Communication Interface		Bidder Mention
	Other Features	Emergency Power Off		Local and remote
		Maintenance Bypass Switch		Built-in and Manual Bypass
Monitoring System		LED Display		
Generator Support		Yes		
Accessories	Electrical wire (Original BRB /Estern /BBS /SQ /Partex /Paradise /Singer etc)	Input Connection : 3 wires (1 Phase + N +G) Output Connection : 3 wires (1 Phase + N +G) Phase wire Color (Red) –6rm Neutral wire Color (Black) –6rm Ground wire Color (Green and Single core) –4rm		
	Circuit Breaker (Original ABB /Legrand /Schneider	1Phase ----- 5Nos		

		etc) and purchase from Local authorized distributor		
		Raw material	DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape.	
	Site Visit	Pre inspection	Site visit preferred, if supplier are interested.	
	Warranty	System Unit & Battery	2 Year Full warranty (System Unit & Battery)	
	Unit Price (Including VAT & IT)	Price are included with Installation Charge, Electrical wire, Circuit Breaker, Raw materials and others if needed.		Tk.

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) **The UPS to be supplied to Hardware Section of ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the PBTI as per terms of the Supply Order on production of a certificate from the concerned PBTI to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the PBTI where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) **Successful bidder** must ensure delivery of UPS **within 15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 09-09-2020** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-

(Md. Aminul Islam)
Asst. General Manager

Sd/-


(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head

OFFERING SHEET

(To be submitted alongwith the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 05(five) KVA Online UPS.

SN	Feature	Product Description	Price	
1	General	True On Line UPS 5KVA, 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		5KVA
	Input	Backup		1 hours (Full Load)
		Input voltage range		120-276Vac (Full Load)
		Nominal Voltage		220Vac (1Phase, 2 wire +G)
		Power Factor		>0.99 (full load)
		Frequency		40~70Hz (Auto detect)
		Input Phase		1 Phase
		Current THDi		< 5% at non-linear load
		Bypass Voltage Range		Max. Voltage: +15% Min. voltage : -45% Frequency protection range: ±10%
		ECO Range		Same as the bypass
		Generator Input		Support
	Output	Output Phase		1 Phase and Ground
		Output voltage range		220volt ±1%
		Voltage Regulation		±2%
		Frequency		50Hz
		THD		≤2% with linear load ≤5% with non-linear load
		Crest Factor		3:1
		Power Factor		0.8
		Overload Capacity		≤105%: continuous; 106%~110%:10 minute; 111%~125%:1 minute; 125%~150%:30 seconds
	Battery & Charger	Waveform		Pure Sinewave
		System Unit Voltage		192/216/240Vdc configurable front LCD panel
		Quantity		16Pcs/18Pcs/20Pcs
		Capacity		Bidder Mention
		Battery Type		Sealed Maintenance Free (SMF)
	Conformance	Charge Current		Built-in :1A or Higher
		Safety		CE
	Efficiency	AC-AC		≥90%
		ECO Mode		≥98%
	Environment	Operating Temperature		0~45°C
		Storage Temperature		-25~55°C
		Relative Humidity		0~95% (non-condensing)
		Audible Noise		<60dB (at 1 meter)
	Communication Interface	Communication Interface		Bidder Mention
	Other Features	Emergency Power Off		Local and remote
		Maintenance Bypass Switch		Built-in and Manual Bypass
		Monitoring System		LED Display
		Generator Support		Yes
Accessories	Electrical wire (Original BRB /Estern /BBS /SQ	Input Connection : 3 wires (1 Phase + N +G) Output Connection : 3 wires (1 Phase + N +G)		

	/Partex /Paradise /Singer etc)	Phase wire Color (Red) –6mm Neutral wire Color (Black) –6mm Ground wire Color (Green and Single core) –4mm	
	Circuit Breaker (Original ABB /Legrand /Schneider etc) and purchase from Local authorized distributor	1Phase ----- 5Nos	
	Raw material	DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape.	
Site Visit	Pre inspection	Site visit preferred, if supplier are interested.	
Warranty	System Unit & Battery	2 Year Full warranty (System Unit & Battery)	
Unit Price (Including VAT & IT)	Price are included with Installation Charge, Electrical wire, Circuit Breaker, Raw materials and others if needed.		Tk.

Authorised Signature