



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/6 KVA ONLINE UPS/ 22/12/20 2020

August 24, 2020

**Notice inviting quotation for supply of 06 (six) KVA
Online UPS for Card Division, Head Office, Dhaka.**

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 06 KVA Online UPS with 3 hours backup for Card Division, Head Office, Dhaka as per following specification.

Specifications of the UPS:

SN	Feature	Product Description
1	General	6kVA Online UPS, 1Phase In & 1Phase Out and Ground
	Brand	Bidder Mention
	Model	Bidder Mention
	Country of Origin	Bidder Mention
	Country of Manufacture	Bidder Mention
	Capacity	6KVA
	Backup	3 Hours Min (Full Load)
	Input	Input voltage range
		120-276Vac (Full Load)
		Nominal Voltage
		220Vac (1Phase, 2 wire +G)
		Frequency
		40~60Hz (Auto detect)
		Input Phase
		1 Phase
	Output	Output Phase
		1 Phase and Ground
		Output voltage range
		220volt ±1%
		Frequency
		50Hz
		Crest Factor
		3:1
		Power Factor
		0.8
		Overload Capacity
		≤105%: continuous; 106%~110%;10 minute; 111%~125%:1 minute; 125%~150%:30 seconds
	Battery & Charger	System Unit Voltage
		192 vdc or higher
		Quantity
		Minimum 16Pcs (80amp) or higher
		Capacity
		Bidder Mention
		Battery Type
		Sealed Maintenance Free (SMF)
		Charge Current
		Built-in :5A or Higher
	Efficiency	AC-AC
		≥90%
		ECO Mode
		≥98%
	Environment	Operating Temperature
		0~45°C
	Communication Interface	Communication Interface
		Bidder Mention
	Others Features	Maintenance Bypass Switch
		Built-in and Manual Bypass
		Monitoring System
		LED Display
		Generator Support
		Yes
	Accessories	Electrical wire (Original BRB /Estern /BBS /SQ /Partex /Paradise /Singer)
		Input Connection : 3 wires (1 Phase + N +G) Output Connection : 3 wires (1 Phase + N +G) Phase wire Color (Red) – 6rm Neutral wire Color (Black) – 6rm

			Ground wire Color (Green and Single core) – 2.5mm
		Circuit Breaker (Original ABB /Legrand /Schneider) and purchase from Local authorized distributor	1Phase ----- 5Nos
		Raw material	DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape.
	Site Visit	Pre inspection	Site visit preferred, if supplier are interested.
	Warranty	System Unit & Battery	2 Year Full warranty (System Unit & Battery)

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Card Division as per terms of the Supply Order on production of a certificate from the concerned Division to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the Card Division where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) **Successful bidder must ensure delivery of UPS within 15(fifteen) days of getting work order.**
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

		Monitoring System	LED Display		
		Generator Support	Yes		
	Accessories	Electrical wire (Original BRB /Estern /BBS /SQ /Partex /Paradise /Singer)	Input Connection : 3 wires (1 Phase + N +G) Output Connection : 3 wires (1 Phase + N +G) Phase wire Color (Red) – 6 rm Neutral wire Color (Black) – 6rm Ground wire Color (Green and Single core) – 2.5rm		
		Circuit Breaker (Original ABB /Legrand /Schneider etc) and purchase from Local authorized distributor	1Phase ----- 5Nos		
		Raw material	DB Box, Connector, Lux, Cable tie, Royal Plug, Screw, Electrical Tape.		
	Site Visit	Pre inspection	Site visit preferred, if supplier are interested.		
	Warranty	System Unit & Battery	2 Year Full warranty (System Unit & Battery)		
Unit Price (Including VAT & IT)	Price are included with Installation Charge, Electrical wire, Circuit Breaker, Raw materials and others if needed.				

Authorised Signature

OFFERING SHEET
(To be submitted alongwith the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 06 (six) KVA Online UPS.

Feature	Product Description		Bidder Specification	
General	6kVA Online UPS, 1Phase In & 1Phase Out and Ground			
		Brand	Bidder Mention	
		Model	Bidder Mention	
		Country of Origin	Bidder Mention	
		Country of Manufacture	Bidder Mention	
		Capacity	6KVA	
		Backup	3 Hours Min (Full Load)	
	Input	Input voltage range	120-276Vac (Full Load)	
		Nominal Voltage	220Vac (1Phase, 2 wire +G)	
		Frequency	40~60Hz (Auto detect)	
		Input Phase	1 Phase	
	Output	Output Phase	1 Phase and Ground	
		Output voltage range	220volt \pm 1%	
		Frequency	50Hz	
		Crest Factor	3:1	
		Power Factor	0.8	
		Overload Capacity	\leq 105%: continuous; 106%~110%:10 minute; 111%~125%:1 minute; 125%~150%:30 seconds	
	Battery & Charger	System Unit Voltage	192 vdc or higher	
		Quantity	Minimum 16Pcs (80 Amp.) or higher	
		Capacity	Bidder Mention	
		Battery Type	Sealed Maintenance Free (SMF)	
		Charge Current	Built-in :5A or Higher	
	Environment	Operating Temperature	0~45°C	
	Communication Interface	Communication Interface	Bidder Mention	
		Maintenance Bypass Switch	Built-in and Manual Bypass	

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 09-09-2020** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-
(Md. Aminul Islam)
Asst. General Manager

Sd/-
(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office,
Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

~~CC~~ TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head