



**PUBALI BANK LIMITED**  
**ICT OPERATION DIVISION**  
**HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.**

PBL/HO/ICTOD/QUOTATION/GENERATOR/3658(3)/2022

September 07, 2022

**Notice inviting quotation for supply of 6 KW/7 KW/10 KW Generator  
for different Branches/Sub Branches/Wings/Offices of our Bank.**

Sealed quotations are hereby invited from bonafied Supplier, Trader, Importer of Generator for supply of 6 KW/7 KW/10 KW Generator for different Branches/Sub Branches/Wings/Offices of our Bank all over Bangladesh as per following specifications:

**Specification:**

SN	Feature	Generator 6 KW	Generator 7KW	Generator 10KW
1	Brand	Mention by the bidder		
2	Model	Mention by the bidder		
3	Maximum Output	6.5KW	7.5KW	11KW
4	Output Load Amp	27A	32A	45A
5	Frequency	50Hz	50Hz	50Hz
6	No. of Phase, AC Voltage	1 Phase, 220 Volts	1 Phase, 220 Volts	1 Phase, 220 Volts
7	Power Factor	1 Cos	1 Cos	1 Cos
8	Voltage Regulator System	AVR	AVR	AVR
9	Engine Model	Mention by the bidder	Mention by the bidder	Mention by the bidder
10	Engine Type	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled
11	Displacement	420cc	460cc	688cc
12	Speed	3600rpm	3600rpm	3600rpm
13	Maximum Engine Power	10.5KW / 14hp	12.0KW / 16hp	18KW / 24hp
14	No of Cylinder	1 Cylinder	1 Cylinder	2 Cylinder
15	IGNITION SYSTEM	Non-Contact Transistorize Magneto	Non-Contact Transistorize Magneto	Non-Contact Transistorize magneto
16	STARTING SYSTEM	Recoil & Electric	Recoil & Electric	Electric
17	FUEL TANK CAPACITY	30 Ltrs	25 Ltr	30Ltr
18	CONTINUOUS OPERATION HOUR	2.5 Ltr/Hr	3 Ltr/Hr	6Hr
19	FUEL CONSUMPTION	10 Hr	8.3 Hr	5Ltr/Hr
20	ENGINE OIL CAPACITY	1.1 Ltr	1.2 Ltr	2Ltr
21	NOISE LEVEL @7M	72dBA	72 dBA	Noise Level @7m: 80dBA
22	Warranty	2 Years	2 Years	2 Years
23	Price (Including VAT, AIT, Security money, delivery, Installation etc)			



**Terms and conditions:**

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Interested supplier/trader/importer may participate in both or individual specification of Generator.
- 3) In case of any trouble with the Generator within the warranty period the supplier shall have to replace/repair the Generator free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the Generator is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 4) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Branch/ Office as per terms of the Supply Order on production of a certificate from the concerned branch/ office to the effect that the Generator is supplied in good condition as per Supply Order and is working properly.
- 5) **10% (ten percent)** of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 6) **All Tax, Vat, Govt. Duties etc.** will be deducted from the bill as per rule prior to payment of the same.
- 7) **Successful bidder must ensure delivery of Generators within 15 (fifteen) days of getting work order.**
- 8) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 9) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank is the prime factors for consideration.
- 10) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the Generator.
- 11) Photocopy of Trade License, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer/Bid to be dropped in the Tender Box kept in **Establishment Division**, Pubali Bank Limited, Head Office, 12<sup>th</sup> Floor, 26 Dilkusha C/A, Dhaka **by 11-00 a.m.** up to **21-09-2022** which will be opened on the same day at 11.30 a.m. in presence of the bidders (if any).

Sd/-

**(Md. Aminul Islam)**  
**Asst. General Manager**

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : [www.pubalibangla.com](http://www.pubalibangla.com)

  
**Asst. General Manager**

Sd/-

**(Md. Helal Uddin)**  
**GM & Division Head**

  
**GM & Division Head**



# OFFERING SHEET

(To be submitted along with the offer)

Tenderer's name :

Address :

## Tender Notice for Supply of 6 KW/7 KW/10 KW Generator

SN	Feature	Generator 6 KW	Generator 7KW	Generator 10KW
1	Brand	Mention by the bidder		
2	Model	Mention by the bidder		
3	Maximum Output	6.5KW	7.5KW	11KW
4	Output Load Amp	27A	32A	45A
5	Frequency	50Hz	50Hz	50Hz
6	No. of Phase, AC Voltage	1 Phase, 220 Volts	1 Phase, 220 Volts	1 Phase, 220 Volts
7	Power Factor	1 Cos	1 Cos	1 Cos
8	Voltage Regulator System	AVR	AVR	AVR
9	Engine Model	Mention by the bidder	Mention by the bidder	Mention by the bidder
10	Engine Type	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled	4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled
11	Displacement	420cc	460cc	688cc
12	Speed	3600rpm	3600rpm	3600rpm
13	Maximum Engine Power	10.5KW / 14hp	12.0KW / 16hp	18KW / 24hp
14	No of Cylinder	1 Cylinder	1 Cylinder	2 Cylinder
15	IGNITION SYSTEM	Non-Contact Transistorize Magneto	Non-Contact Transistorize Magneto	Non-Contact Transistorize magneto
16	STARTING SYSTEM	Recoil & Electric	Recoil & Electric	Electric
17	FUEL TANK CAPACITY	30 Ltrs	25 Ltr	30Ltr
18	CONTINUOUS OPERATION HOUR	2.5 Ltr/Hr	3 Ltr/Hr	6Hr
19	FUEL CONSUMPTION	10 Hr	8.3 Hr	5Ltr/Hr
20	ENGINE OIL CAPACITY	1.1 Ltr	1.2 Ltr	2Ltr
21	NOISE LEVEL @7M	72dBA	72 dBA	Noise Level @7m: 80dBA
22	Warranty	2 Years	2 Years	2 Years
23	Price (Including VAT, AIT, Security money, delivery, Installation etc)			

-----  
**Authorized Signature**