




INVITATION FOR TENDER

Sealed Tender is hereby invited from the eligible Tenderers as mentioned in the tender documents for the under mentioned work as per terms & conditions stated below:

| | | | |
|-----|---|--|---|
| 1. | Procuring Entity | Pubali Bank Limited, ICT Operation Division, Head Office, 26 Dilkusha Commercial Area, Dhaka-1000. | |
| 2. | Tender Name | Purchasing 60 (Sixty) KVA Online Modular UPS for Disaster Recovery Center of Pubali Bank Limited. | |
| 3. | Price of the Tender Documents | Tk.1,000/= (Taka One Thousands) only for each Tender Documents (non-refundable) | |
| 4. | Eligibility of Tenderers | i) | The Bidder must be an authorized distributor/reseller of the product. |
| | | ii) | Having valid Trade License up to date, Income Tax Clearances Certificate and VAT Registration certificate. |
| | | iii) | Must be financially solvent (solvency certificate to be submitted). |
| 5. | Amount of Tender Security | Bidder must be deposited 5% of bid money as Tender Security deposited in the form of Payment Order/Bank Guarantee in favor of Pubali Bank Limited which to be refunded to the unsuccessful bidders. No Tender will be considered without Tender Security (Earnest Money). | |
| 7. | Tender Documents to be obtained from | Pubali Bank Limited, ICT Operation Division, Head Office (10 th Floor), 26 Dilkusha Commercial Area, Dhaka-1000. | |
| 8. | Tender Documents to be submitted to | Pubali Bank Limited, Establishment Division , Head Office (7 th Floor), 26 Dilkusha Commercial Area, Dhaka-1000. | |
| 9. | Last date and time for selling tender documents | Up to 06:00 PM (BST) : 15 October 2019 | |
| 10. | Last date and time for tender submission | Up to 11:00 AM (BST) : 16 October 2019 | |
| 11. | Date and time for tender opening | At 11:30 AM (BST) : 16 October 2019 in presence of bidder (if any). | |
| 12. | Special Instruction | i) | Tender document along with an MS Excel calculation Sheet to be submitted in sealed envelope. |
| | | ii) | Pubali Bank Limited reserves the right to accept or reject any/all tender(s) prior to acceptance without assigning any reason whatsoever and is not bound to accept the lowest quotation. |
| | | iii) | Lowest price is not the only criteria to accept the bid. Quality of the offered items, financial capability, and reputation etc. of the firm as assessed by the Bank are the prime factors for consideration. |


(Md. Helal Uddin)
GM & Division Head





PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/60 KVA ONLINE MODULAR UPS/2019 / 2019 September 29, 2019

Notice inviting quotation for supply of 01 (one) unit 60 (Sixty) KVA Online Modular UPS for Disaster Recovery Center, Uttara, Dhaka.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 60 KVA Online Modular UPS for Disaster Recovery Center, Uttara, Dhaka of our Bank as per following specification.

Specifications of the UPS:

Brand : Mentioned by the bidder, **Model:** Mentioned by the bidder, **Country of Origin:** EU/UK/USA/ Germany/Japan/Switzerland, **Country of Manufacture :** EU/UK/USA/Germany/Japan/Switzerland, **Capacity :** 60KVA, **System Frame:** 120 KVA or Higher, **Single Power Module Capacity:** Minimum 20KVA or Higher, **Number of Modules:** Minimum 3 or Higher, **Cabinet Type:** Mention by the bidder, **Waveform:** Pure Sine Wave, **Display:** Digital Display, **Parallel Controller of Cabinet:** Built in, **Modularity:** Mention by the bidder, **Input Nominal voltage :** 380/400/415Vac (3Phase, 4-wire+G), **Input voltage range :** 305-477Vac, **Input Current Harmonic Distortion:** <3%, **Input Power factor :** >0.8, **Input Frequency:** 50/60Hz, **Output Voltage :** 380/400/415Vac (3Phase, 4-wire+G), **Output Power factor :** 1 (KVA=KW), **Output Voltage Harmonic Distortion :** ≤2% (linear load), **Voltage Regulation:** ±1% (Static), **Output Frequency :** 50Hz, **Frequency Regulation :** ±0.05Hz, **Overload Capacity:** ≤ 125%: 10minutes, ≤ 150%: 1minute, **Static stability:** ±1, **Interface:** Mention by the bidder, **SNMP (Built-in):** SNMP Ipv6 card, **Bypass:** Manual/Automatic, **Batteries Type:** SMF (EU Standard), **Battery Capacity:** Standard Backup (15 minutes in full load), **Battery Weight:** Mention by the bidder, **System Voltage:** Mention by the bidder, **Recharge Time:** Mention by the bidder, **Battery backup time:** 15 minutes in full load, **Battery Bank:** Bidder Mention, **Event Log:** Bidder mention, **Cabinet weight (kg) (without power module & Battery unit):** Bidder mention, **Dimensions:** Mention by the bidder, **Online efficiency:** Up to 96.5%, **ECO Mode efficiency:** Up to 99%, **Product supply, installation & Commission:** Charge included with total price, **Accessories:** MDB to UPS input and UPS to Dboutput both are 1x50 rm NYY (3P+N) and 1x35 rm BYA for Grounding. DB Box, Circuit Breaker, Cable lux, nut, bolt, Cable tie, other accessories and supplier are requested to pre inspect site visit, **Product Training:** Locally arrange Technical product training by Certified Trainer, **Warranty:** 03 Years full warranty (System & Battery both).

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) After testing and verification the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned Office.
- 4) Bidder must submit 5% of total bid amount in the form of Payment Order/ Bank Guarantee favoring Pubali Bank Limited, Head Office, Dhaka-1000 with the quotation. "No tender will be considered without tender Security (Earnest Money)".
- 5) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period of 03 (three) years at the satisfaction of the purchaser. Security money may be PO or Bank Guarantee.
- 6) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 7) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after

delivery of the same at the Disaster Recovery Center, Uttara, Dhaka as per terms of the Supply Order.

- 8) In case of any trouble with the UPS within the warranty period the supplier shall have to replace /repair the UPS free of cost at the premises where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 9) Supplier will complete the supply and installation within 15 (fifteen) days of obtaining work order.
- 10) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 11) **Bank is not bound** to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment Division, Pubali Bank Limited, Head Office, 7th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 16-10-2019** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-
(Md. Aminul Islam)
Asst. General Manager

Sd/-
(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head

OFFERING SHEET
(To be submitted along with the offer)

Tenderer's Name :

Address :

Technical Specifications of 60 KVA online Modular UPS for our DR Center, Uttara

| Specification | Description | Bidder Mention |
|--------------------------------|--|----------------|
| Brand | Mention By Bidder | |
| Model | Mention By Bidder | |
| Capacity | 60 KVA | |
| System Frame | 120 KVA or Higher | |
| Country of origin | EU /UK /USA /Germany /Japan / Switzerland | |
| Country of Manufacture | EU /UK /USA /Germany /Japan / Switzerland | |
| Single Power Module Capacity | Minimum 20KVA or Higher | |
| Number of Modules | Minimum 3 or Higher | |
| Cabinet Type | Mention By Bidder | |
| Waveform | Pure Sine Wave | |
| Display | Digital Display | |
| Parallel Controller of Cabinet | Built in | |
| Modularity | Mention By Bidder | |
| Input | | |
| Nominal Voltage | 380V,400V,415Vac (3 phase, 4-wire +G) | |
| Voltage range | 305~477 Vac | |
| Current Harmonic Distortion | < 3% | |
| Power Factor | > 0.8 | |
| Frequency | 50/60 Hz | |
| OUTPUT | | |
| Voltage | 380V,400V, 415Vac (3 phase, 4-wire +G) | |
| Output Power Factor | 1 (kVA=kW) | |
| Voltage Harmonic Distortion | ≤ 2% (linear load) | |
| Voltage Regulation | ± 1% (static) | |
| Frequency | 50 Hz | |
| Frequency Regulation | ± 0.05 Hz | |
| Overload Capacity | ≤ 125%: 10 minutes; ≤ 150%: 1 minute | |
| Static stability Interface | ±1 Mention By Bidder | |

| | | |
|---|--|--|
| SNMP (Built-in) | SNMP IPv6 card | |
| Bypass | Manual / Automatic | |
| Batteries | | |
| Type | SMF (EU Standard) | |
| Battery Capacity | Standard backup | |
| Battery Weight | Bidder mention | |
| System Voltage | Bidder Mention | |
| Recharge Time | Bidder Mention | |
| Battery Backup Time | 15 minutes in full Load | |
| Battery Bank | Bidder Mention | |
| Others feature | | |
| Event Log | Bidder Mention | |
| Ambient Temperature | 0°C / +45°C | |
| Cabinet Weight (kg) (without Power Module & Battery Unit) | Mention By Bidder | |
| Dimensions (WxDxH) | Mention By Bidder | |
| Online Efficiency | Up to 96.5% | |
| ECO Mode Efficiency | Up to 99% | |
| Product Supply, Installation & Commission | Charge Included with Total Price | |
| Accessories (Charge Included with Total Price) | MDB to UPS input and UPS to DB output both are 1x50 mm NYY (3P+N) and 1x35 mm BYA for Grounding. DB Box, Circuit Breaker, Cable lugs, nut, bolt, cable tie, other accessories and supplier are requested to pre inspect site visit. | |
| Product Training | Locally arrange Technical Product Training by Certified Trainer. | |
| Warranty | 03 Years full warranty (System & battery both.) | |
| | | |