

PUBALI BANK LIMITED

ICT OPERATION DIVISION HEAD OFFICE, 26 DILKUSHA-C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/20 KVA ONLINE UPS/

October 24, 2022

Notice inviting quotation for supply of 20 (Twenty) KVA
Online UPS for Foreign Exchange Branch, 24 Motijheel C/A, Dhaka.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 20 KVA Online UPS for Foreign Exchange Branch, Dhaka as per following specification.

Specifications of the UPS:

	Product Specifica	LIOII	
Brand	APC /RIELLO /ABB /ENSMART		
Model	Bidder mention		
Country of Manufacture	Bidder mention		
Capacity	20KVA (3/1 Phase)		
Backup Time	30 Minute backup at full load		
Input	Voltage range	380/400/415 VAC	
	Frequency Range	46Hz-54Hz	
Output	Output Voltage	220VAC	
	Frequency Range	50Hz	
	Transfer Time	Line mode to Battery mode Zero	
	Waveform (Battery Mode)	Pure Sine Wave	
	System Voltage	240 Volt or more	
Battery	Battery Type	SMF	
	Numbers of Battery	Minimum 20Pcs	
	Battery Amp	Bidder mention	
	Typical Recharge Time	Bidder mention	
Noise Level	<60dB		
Generator Support	Yes		
Indicators	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions	
Management	SNMP (Built-in)	Power management from SNMP manager and browser	
Connection	Input Connection	5 wires, 3 phase + N + PE	
	Output Connection	3 wires, 1 phase + N + PE	
Maintenance Bypass	Manual with Ckt Breaker	Manual with Ckt Breaker	
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.		
Warranty	02 Years full (System Unit + Battery)	riginal Melanamy). To A	
Unit Price	Price will Included with VAT, AIT & Security Money.		

Detail specification along with brochure gram of the UPS to be furnished with the Quotations.

2/

of 2

Terms and conditions:

- 1) The offer must be submitted through "Offering Sheet" enclosed with the schedule.
- 2) Bidder must be an authorized distributor/reseller of the product.
- 3) The UPS to be supplied to Hardware Section of **ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) 10% (ten percent) of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Branch as per terms of the Supply Order on production of a certificate from the concerned Branch to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the Branch where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) Successful bidder must ensure delivery of UPS within 15 (fifteen) days of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, and reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the <u>Tender Box kept in Establishment Division</u>, <u>Pubali Bank Limited</u>, <u>Head Office</u>, 12th <u>Floor</u>, 26 <u>Dilkusha C/A</u>, <u>Dhaka by 11-00 a.m. up to 09-11-2022</u> which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-

(Md. Aminul Islam)

Asst. General Manager

Asst. General Manager

Sd/-

(Md. Helal Uddin)

GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office,

Dhaka for information and necessary action.

CC TO Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC10 : www.pubalibangla.com

C

GM & Division Head

OFFERING SHEET

(To be submitted along with the offer)

Tenderer's Na	JIIIC	i
---------------	-------	---

Address

Tender Notice for Supply of 20 KVA Online UPS for Foreign Exchange Branch, Dhaka

Product Specification					
Brand	APC /RIELLO /ABB /ENSMART				
Model	Bidder mention				
Country of Manufacture	Bidder mention				
Capacity -	20KVA (3/1 Phase)				
Backup Time	30 Minute backup at full load				
Input		Voltage range	380/400/415 VAC		
		Frequency Range	46Hz-54Hz		
Output		Output Voltage	220VAC		
		Frequency Range	50Hz		
		Transfer Time	Line mode to Battery mode Zero		
		Waveform (Batt. Mode)	Pure Sine Wave		
		System Voltage	240 Volt		
Battery		Battery Type	SMF		
		Numbers of Battery	Minimum 20Pcs		
		Battery Amp	Bidder mention		
		Typical Recharge Time	Bidder mention		
Noise Level	<60Db				
Generator Support	Yes				
Indicators		LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions		
Management		SNMP (Built-in)	Power management from SNMP manager and web browser		
Connection		Input Connection	5 wires, 3 phase + N + PE		
		Output Connection	3 wires, 1 phase + N + PE		
Maintenance Bypass	Manual with Circuit Breaker				
Accessories	Electrical wire (R/Y/B/K/G), connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.				
Warranty	02 Years full (System Unit + Battery)				
Unit Price (Include VAT, AIT & Security Money)	Price will Included with Installation charge @Motijheel C/A.				