



**PUBALI BANK PLC**  
**ICT OPERATION DIVISION**  
**HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.**

PBPLC/HO/ICTOD/QUOTATION/UPS/ *199/19* / 2023

October 30, 2023

**Notice inviting quotation for supply of 1 (One) KVA Long Backup online UPS  
for different Branches/Sub-Branches/Offices of Pubali Bank PLC.**

Sealed quotations are hereby invited from bonafide Manufacture or its Agent, Supplier, Trader of UPS for supply of 1 (One) KVA Long Backup online UPS for different Branches/Sub-Branches/Offices of Pubali Bank PLC all over Bangladesh as per following specifications.

**Specifications of the UPS (AVR Built in) :**

SN	Feature	Product Description	Price	
1	General	Online UPS 1KVA ( <b>Low Frequency</b> ), 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		1 KVA ( <b>Low Frequency</b> )
		Backup		3 Hours (Full Load) at 900W Heater test.
	Input	Input voltage range	110-300Vac (Full Load)	
		Input Phase	1 Phase	
		Generator Support	Yes	
	Output	Output Phase	1 Phase and Ground	
		Output voltage range	220VAC $\pm$ 5%	
		Frequency	50Hz	
		Power Factor	0.9	
	Battery & Charger	Battery Type	<b>Deep Cycle Batteries (VRLA)</b> (Batteries won't get damaged even in deep discharge condition)	
		System Unit Voltage	36Vdc or more	
		Battery Brand	<b>DIAMEC /LONG /LEOCH</b>	
		Backup Time	3 Hours	
		Battery Weight (Minimum)	80A – 23Kg or more weight.	
		Quantity	3	
		Capacity	Minimum 80A or more	
		Battery Type	Sealed Maintenance Free (SMF)	
		Charge Current	Built-in : 7A or Higher	
	Delivery	Quality & Technical Test	After qualify the sample UPS, each UPS send to Hardware Department, ICTOD, HO before delivery to Branches, due to sample UPS & delivery UPS should be same.	
	Warranty	Warrant Policy	<b>One to One replacement</b>	
		Warrant Period (System Unit)	2 Year Full warranty	
		Warrant Period (Battery Unit)	2 Year Full warranty	
	Unit Price (Including VAT & IT)	Price are included with Installation Charge, Delivery Charge, VAT & IT and others accessories if needed.		Tk.



*21.10.23*

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

**Terms and conditions:**

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) The UPS will be under comprehensive Warranty for **full 2(two) years** or above from the date of supply.
- 3) The UPS to be supplied to Hardware Section of ICT Operation Division, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent)** of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 7) Payment of the bills of different Divisions will be made from ICT Operation Division after delivery of the same as per terms of the Supply Order.
- 8) Principal Offices, Regional Offices, Corporate Branches, Branches and Sub-Branches will issue supply order for their own requirement and will make payment directly through online.
- 9) **Successful bidder must have an account i.e. SB/CD/CC at any Branch of our Bank for receiving their payment through online.**
- 10) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 11) **Successful bidder must ensure delivery of UPSs within 15 (fifteen) days of getting workorder.**
- 12) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 13) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the UPS.
- 14) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.



Offer / Bid to be dropped in the **Tender Box kept in Establishment and General Services Division, Pubali Bank PLC, Head Office, 12<sup>th</sup> Floor, 26 Dilkusha C/A, Dhaka by 11:00 a.m. On 15-11-2023** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any)..

Sd/-

(Md. Aminul Islam)  
Asst. General Manager

Sd/-

(Md. Helal Uddin)  
GM & Division Head


CC TO : The Member Secretary, Purchase Committee, Pubali Bank PLC, Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank PLC, Head Office, Dhaka.

CC TO : [www.pubalibangla.com](http://www.pubalibangla.com)



Asst. General Manager



GM & Division Head

**OFFERING SHEET**  
(To be submitted along with the offer)

Tenderer's Name :

Address :

**Tender Notice for Supply of 01KVA (900W) Long Backup Online UPS (Heater Load Test).**

SN	Feature	Product Description	Price	
1	General	Online UPS 1KVA ( <b>Low Frequency</b> ), 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		1 KVA ( <b>Low Frequency</b> )
		Backup		3 Hours (Full Load) at 900W Heater test.
	Input	Input voltage range		110-300Vac (Full Load)
		Input Phase		1 Phase
		Generator Support		Yes
	Output	Output Phase		1 Phase and Ground
		Output voltage range		220VAC ±5%
		Frequency		50Hz
		Power Factor		0.9
	Battery & Charger	Battery Type		<b>Deep Cycle Batteries (VRLA)</b> (Batteries won't get damaged even in deep discharge condition)
		System Unit Voltage		36Vdc or more
		Battery Brand		<b>DIAMEC /LONG /LEOCH</b>
		Backup Time		3 Hours
		Battery Weight (Minimum)		80A – 23Kg or more weight.
		Quantity		3
		Capacity		Minimum 80A or more
		Battery Type		Sealed Maintenance Free ( <b>SMF</b> )
		Charge Current		Built-in : <b>7A</b> or Higher
	<b>Delivery</b>	Quality & Technical Test		After qualify the sample UPS, each UPS send to Hardware Department, ICTOD, HO before delivery to Branches, due to sample UPS & delivery UPS should be same.
	<b>Warranty</b>	Warrant Policy		<b>One to One replacement</b>
		Warrant Period (System Unit)		2 Year Full warranty
		Warrant Period (Battery Unit)		2 Year Full warranty
<b>Unit Price</b> (Including VAT & IT)	Price are included with Installation Charge, Delivery Charge, VAT & IT and others accessories if needed.	Tk.		

**Authorized Signature**