



PUBALI BANK PLC.
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

BPBLC/HO/ICTOD/QUOTATION/3 KVA ONLINE UPS/ *AM 23/13* / 2023

December 07, 2023

Notice inviting quotation for supply of 03KVA Online UPS for Branches/ ATM Booths of our Bank.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 3 KVA Online UPS for different Branches/ATM Booths of our Bank as per following specification.

Specification for 3KVA (10/10) Online UPS:

SN	Feature	Product Description	Price	
1	General	Online UPS 3KVA (Low Frequency), 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		3 KVA (Low Frequency)
		Backup		3 Hours (Full Load) at 2700W Heater test.
	Input	Input voltage range		110-300Vac (Full Load)
		Input Phase		1 Phase
		Generator Support		Yes
	Output	Output Phase		1 Phase and Ground
		Output voltage range		220VAC \pm 5%
		Frequency		50Hz
		Power Factor		0.9
	Battery & Charger	Battery Type		Deep Cycle Batteries (VRLA) (Batteries won't get damaged even in deep discharge condition)
		System Unit Voltage		96V dc or more
		Battery Brand		DIAMEC /LONG /LEOCH
		Backup Time		3 Hours
		Battery Weight (Minimum)		Bidder Mention
		Quantity		8
		Capacity		Bidder Mention
		Battery Type		Sealed Maintenance Free (SMF) RICSHA BATTERY NOT ALLOW
	Charge Current	Built-in : 7A or Higher		
	Delivery	Quality & Technical Test		After qualify the sample UPS, each UPS send to Hardware Department, ICTOD, HO before delivery to Branches, due to sample UPS & delivery UPS should be same.
	Warranty	Warrant Policy		One to One replacement
		Warrant Period (System Unit)		2 Year Full warranty
		Warrant Period (Battery Unit)		2 Year Full warranty
	Unit Price (Including VAT & IT)	Price are included with Installation Charge, Delivery Charge, VAT & IT and others accessories if needed.		T

Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Bidder must be an authorized **distributor/reseller** of the product.
- 3) **The UPS to be supplied to Hardware Section of ICT Operation Division**, Head Office, Dhaka for testing and verification. After testing the UPS by ICT Operation Division, Head Office successful bidder will supply the UPS to the concerned branch.
- 4) **10% (ten percent) of the bill** amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.



- 5) All Tax, Vat, Govt. Duties etc. will be deducted from the bill as per rule prior to payment of the same.
- 6) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the PBTI as per terms of the Supply Order on production of a certificate from the concerned PBTI to the effect that the UPS is supplied in good condition as per Supply Order and is working properly.
- 7) In case of any trouble with the UPS within the warranty period the supplier shall have to replace/repair the UPS free of cost at the premises the PBTI where it will be supplied within 24(twenty four) hours. If the UPS is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 8) **Successful bidder must have an account i.e. SB/CD/CC at any Branch of our Bank for receiving their payment through online** and ensure delivery of UPS **within 15(fifteen) days** of getting work order.
- 9) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 10) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, and reputation etc. of the firm as assessed by the Bank are the prime factors for consideration.
- 11) The successful bidder shall have to inform the Bank **1(one) month before** if they want to discontinue supply of the UPS.
- 12) Photocopy of Trade License, BSTI Certificate, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer / Bid to be dropped in the **Tender Box kept in Establishment and General Services Division, Pubali Bank PLC., Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka by 11-00 a.m. up to 24-12-2023** which will be opened on the same day at 11.30 a.m. in presence of the bidders present (if any).

Sd/-

(Md. Aminul Islam)
Asst. General Manager

Sd/-

(Md. Helal Uddin)
GM & Division Head

CC TO : The Member Secretary, Purchase Committee, Pubali Bank PLC., Head Office,
Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank PLC., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager


GM & Division Head

OFFERING SHEET
(To be submitted along with the offer)

Tenderer's Name :

Address :

Tender Notice for Supply of 03KVA Long Backup Online UPS (Heater Load Test) for Branches/ ATM Booth.

SN	Feature	Product Description	Price	
1	General	Online UPS 3KVA (Low Frequency), 1Phase In & 1Phase Out and Ground	Tk.	
		Brand		Bidder Mention
		Model		Bidder Mention
		Country of Origin		Bidder Mention
		Country of Manufacture		Bidder Mention
		Capacity		3 KVA (Low Frequency)
	Input	Backup		3 Hours (Full Load) at 2700W Heater test.
		Input voltage range		110-300Vac (Full Load)
		Input Phase		1 Phase
	Output	Generator Support		Yes
		Output Phase		1 Phase and Ground
		Output voltage range		220VAC \pm 5%
		Frequency		50Hz
	Battery & Charger	Power Factor		0.9
		Battery Type		Deep Cycle Batteries (VRLA) (Batteries won't get damaged even in deep discharge condition)
		System Unit Voltage		96V dc or more
		Battery Brand		DIAMEC /LONG /LEOCH
		Backup Time		3 Hours
		Battery Weight (Minimum)		Bidder Mention
		Quantity		8
		Capacity		Bidder Mention
	Delivery	Battery Type		Sealed Maintenance Free (SMF) RISHA BATTERY NOT ALLOW
		Charge Current		Built-in : 7A or Higher
Warranty	Quality & Technical Test	After qualify the sample UPS, each UPS send to Hardware Department, ICTOD, HO before delivery to Branches, due to sample UPS & delivery UPS should be same.		
	Warrant Policy	One to One replacement		
	Warrant Period (System Unit)	2 Year Full warranty		
Unit Price (Including VAT & IT)	Warrant Period (Battery Unit)	2 Year Full warranty		
	Price are included with Installation Charge, Delivery Charge, VAT & IT and others accessories if needed.			
			Tk.	

Authorized Signature