



PUBALI BANK LIMITED
ICT OPERATION DIVISION
HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/GENERATOR/3658(3)/2022

September 07, 2022

**Notice inviting quotation for supply of 6 KW/7 KW/10 KW Generator
for different Branches/Sub Branches/Wings/Offices of our Bank.**

Sealed quotations are hereby invited from bonafied Supplier, Trader, Importer of Generator for supply of 6 KW/7 KW/10 KW Generator for different Branches/Sub Branches/Wings/Offices of our Bank all over Bangladesh as per following specifications:

Specification:

| SN | Feature | Generator 6 KW | Generator 7KW | Generator 10KW |
|----|------------------------------------------------------------------------|---------------------------------------------------------------------|---------------------------------------------------------------------|---------------------------------------------------------------------|
| 1 | Brand | Mention by the bidder | | |
| 2 | Model | Mention by the bidder | | |
| 3 | Maximum Output | 6.5KW | 7.5KW | 11KW |
| 4 | Output Load Amp | 27A | 32A | 45A |
| 5 | Frequency | 50Hz | 50Hz | 50Hz |
| 6 | No. of Phase, AC Voltage | 1 Phase, 220 Volts | 1 Phase, 220 Volts | 1 Phase, 220 Volts |
| 7 | Power Factor | 1 Cos | 1 Cos | 1 Cos |
| 8 | Voltage Regulator System | AVR | AVR | AVR |
| 9 | Engine Model | Mention by the bidder | Mention by the bidder | Mention by the bidder |
| 10 | Engine Type | 4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled | 4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled | 4-Stroke OHV Single-cylinder gasoline engine with forced air-cooled |
| 11 | Displacement | 420cc | 460cc | 688cc |
| 12 | Speed | 3600rpm | 3600rpm | 3600rpm |
| 13 | Maximum Engine Power | 10.5KW / 14hp | 12.0KW / 16hp | 18KW / 24hp |
| 14 | No of Cylinder | 1 Cylinder | 1 Cylinder | 2 Cylinder |
| 15 | IGNITION SYSTEM | Non-Contact Transistorize Magneto | Non-Contact Transistorize Magneto | Non-Contact Transistorize magneto |
| 16 | STARTING SYSTEM | Recoil & Electric | Recoil & Electric | Electric |
| 17 | FUEL TANK CAPACITY | 30 Ltrs | 25 Ltr | 30Ltr |
| 18 | CONTINUOUS OPERATION HOUR | 2.5 Ltr/Hr | 3 Ltr/Hr | 6Hr |
| 19 | FUEL CONSUMPTION | 10 Hr | 8.3 Hr | 5Ltr/Hr |
| 20 | ENGINE OIL CAPACITY | 1.1 Ltr | 1.2 Ltr | 2Ltr |
| 21 | NOISE LEVEL @7M | 72dBA | 72 dBA | Noise Level @7m: 80dBA |
| 22 | Warranty | 2 Years | 2 Years | 2 Years |
| 23 | Price (Including VAT, AIT, Security money, delivery, Installation etc) | | | |



Terms and conditions:

- 1) The offer must be submitted through "**Offering Sheet**" enclosed with the schedule.
- 2) Interested supplier/trader/importer may participate in both or individual specification of Generator.
- 3) In case of any trouble with the Generator within the warranty period the supplier shall have to replace/repair the Generator free of cost at the premises the Branch/Office where it will be supplied within 24(twenty four) hours. If the Generator is not in repairable condition on the premises, it should be replaced by a similar one within 24 (twenty four) hours from getting the information of trouble prior to bring the same at their end for repairing purpose. In case of failure of the supplier, the Bank shall have the right to get the replacement or repairing works done by other agency at the cost of the supplier. Such costs will be adjusted from the supplier's security money and the supplier shall have no objection to it.
- 4) Payment of the bills will be made from ICT Operation Division, Head Office, Dhaka after delivery of the same at the Branch/ Office as per terms of the Supply Order on production of a certificate from the concerned branch/ office to the effect that the Generator is supplied in good condition as per Supply Order and is working properly.
- 5) **10% (ten percent)** of the bill amount will be retained as Security Money which will be paid to the supplier after expiry of the warranty period at the satisfaction of the purchaser.
- 6) **All Tax, Vat, Govt. Duties etc.** will be deducted from the bill as per rule prior to payment of the same.
- 7) **Successful bidder must ensure delivery of Generators within 15 (fifteen) days of getting work order.**
- 8) The authority reserves the right to accept or reject all or any offer without assigning any reason.
- 9) Bank is not bound to accept the lowest Quotation. To be successful in the bid, quality of the offered items, financial capability, reputation etc. of the firm as assessed by the Bank is the prime factors for consideration.
- 10) The successful bidder shall have to inform the Bank 1(one) month before if they want to discontinue supply of the Generator.
- 11) Photocopy of Trade License, TIN Certificate, VAT registration Certificate (if any), Financial Solvency Certificate (if any), Appreciation letter, Major client List and Company profile to be submitted with the Quotation.

Offer/Bid to be dropped in the Tender Box kept in **Establishment Division**, Pubali Bank Limited, Head Office, 12th Floor, 26 Dilkusha C/A, Dhaka **by 11-00 a.m.** up to **21-09-2022** which will be opened on the same day at 11.30 a.m. in presence of the bidders (if any).

Sd/-

(Md. Aminul Islam)
Asst. General Manager

CC TO : The Member Secretary, Purchase Committee, Pubali Bank Ltd., Head Office, Dhaka for information and necessary action.

CC TO : Notice Board, Pubali Bank Ltd., Head Office, Dhaka.

CC TO : www.pubalibangla.com


Asst. General Manager

Sd/-

(Md. Helal Uddin)
GM & Division Head


GM & Division Head