



PUBALI BANK LIMITED

ICT OPERATION DIVISION

HEAD OFFICE, 26 DILKUSHA C/A, DHAKA.

PBL/HO/ICTOD/QUOTATION/10 KVA ONLINE UPS/7662/2018

March 29, 2018

Notice inviting quotation for supply of 10 (ten) KVA Online UPS for Pubali Bank Training Institute of our Bank.

Sealed quotations are hereby invited from bonafide Manufactures or its Agents, Suppliers, Traders of UPS for supplying of 10 KVA Online UPS for Pubali Bank Training Institute of our Bank as per following specification.

Specifications of the UPS:

Product Specification		
Brand	Bidder mention	
Model	Bidder mention	
Country of Manufacture	Bidder mention	
Capacity	10KVA	
Backup Time	2 Hours backup at full load (Inductor / Bulb load)	
Efficiency	To AC Mode	87%
	To Battery Mode	83%
Input	Frequency Range	46Hz-54Hz / 56Hz-64Hz
	Power Factor	0.80 @ nominal voltage (100% load)
	Voltage range	260AC-370AC
BATTERY	Battery Type	Maintenance free battery
	Numbers of Battery	Bidder mention
	Typical Recharge Time	Bidder mention
OUTPUT	Output Voltage	220VAC
	Frequency Range (Synchronized Range)	50 Hz
	Transfer Time	Line mode to Battery mode Zero
	Waveform (Batt. Mode)	Pure Sine Wave
INDICATORS	LED Panel	UPS status, Load level, Battery level, Input / Output voltage, and Fault conditions
MANAGEMENT	Built-in SNMP	Power management from SNMP manager and web browser
	Smart RS-232/USB	Supports Windows® 2000/2003/XP/Vista/2008, Windows® 7, Linux, and MAC
CONNECTION	Input Connection	5 wires, 3 phase + N + PE
	Output Connection	3 wires, 1 phase + N + PE
Accessories	Electrical wire, connector, Circuit Breaker (input + output), DB Box & others if needed. We are request to you for pre inspection site visit.	
Installation charge @ Motijheel	Price will Included with Unit Price	
Warranty	02 Years full (System Unit + Battery)	

Detail specification along with brochure, Circuit Diagram of the UPS to be furnished with the Quotations.

